



Certificate of Analysis

Lab Sample No.: 1308234-01

Name: Rockville Pipeline Co.	Sample Date: 8/27/2013 11:40 AM
Sample Site: 620 East Main	Receipt Date: 8/28/2013 1:00 PM
Comments:	Sampler: Dave Brooks
Sample Type: Drinking Water	System No.: UTAH27014
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analysis Date/Time	Analyst Initials	Analytical Method	Flag
Regulated Haloacetic Acids (HAAs)								
Dibromoacetic Acid	2.5		1.0	ug/L	9/4/2013 6:24	RAH	EPA 552.2	
Dichloroacetic Acid	1.0		1.0	ug/L	9/4/2013 6:24	RAH	EPA 552.2	
Monobromoacetic Acid	ND		1.0	ug/L	9/4/2013 6:24	RAH	EPA 552.2	
Monochloroacetic Acid	ND		2.0	ug/L	9/4/2013 6:24	RAH	EPA 552.2	
Trichloroacetic Acid	ND		1.0	ug/L	9/4/2013 6:24	RAH	EPA 552.2	
Total Haloacetic Acids	3.5	60	2.0	ug/L	9/4/2013 6:24	RAH	EPA 552.2	
Trihalomethanes (THMs)								
Bromodichloromethane	7.3		0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Bromoform	4.2		0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Chloroform	3.3		0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Dibromochloromethane	10.4		0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Total Trihalomethanes	25.2	80	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Volatile Organic Compounds								
1,1,1,2-Tetrachloroethane	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,1,1-Trichloroethane	ND	200	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,1,2,2-Tetrachloroethane	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,1,2-Trichloroethane	ND	5	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,1,2-Trichlorotrifluoroethane	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,1-Dichloroethane	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,1-Dichloroethene	ND	7	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,1-Dichloropropene	ND		0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,2,3-Trichlorobenzene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,2,3-Trichloropropane	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,2,4-Trichlorobenzene	ND	70	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,2,4-Trimethylbenzene	ND	70	1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,2-Dichlorobenzene	ND	600	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,2-Dichloroethane	ND	5	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,2-Dichloropropane	ND	5	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,3,5-Trimethylbenzene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,3-Dichlorobenzene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,3-Dichloropropane	ND		0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
1,4-Dichlorobenzene	ND	75	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
2,2-Dichloropropane	ND		0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
2-Chlorotoluene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
4-Chlorotoluene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Benzene	ND	5	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	