



Certificate of Analysis

CHEMTECH-FORD
LABORATORIES

Lab Sample No.: 1308234-01

Name: Rockville Pipeline Co.	Sample Date: 8/27/2013 11:40 AM
Sample Site: 620 East Main	Receipt Date: 8/28/2013 1:00 PM
Comments:	Sampler: Dave Brooks
Sample Type: Drinking Water	System No.: UTAH27014
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analysis Date/Time	Analyst Initials	Analytical Method	Flag
Volatile Organic Compounds								
Bromobenzene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Bromochloromethane	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Bromodichloromethane	7.3		0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Bromoform	4.2		0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Bromomethane	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Carbon Tetrachloride	ND	5	1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Chlorobenzene	ND	100	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Chloroethane	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Chloroform	3.3		0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Chloromethane	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
cis-1,2-Dichloroethene	ND	70	1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
cis-1,3-Dichloropropene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Dibromochloromethane	10.4		0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Dibromomethane	ND	5	1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Dichlorodifluoromethane	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Ethyl Benzene	ND	700	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Hexachlorobutadiene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Isopropylbenzene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Methyl tert-Butyl Ether (MTBE)	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Methylene Chloride	ND	5	1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Naphthalene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
n-Butyl Benzene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
n-Propyl Benzene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
p-Isopropyltoluene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
sec-Butyl Benzene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Styrene	ND	100	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
tert-Butylbenzene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Tetrachloroethene	ND	5	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Toluene	ND	1000	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
trans-1,2-Dichloroethene	ND	100	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
trans-1,3-Dichloropropene	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Trichloroethene	ND	5	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Trichlorofluoromethane	ND		1.0	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Vinyl Chloride	ND	2	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	
Xylenes, total	ND	10000	0.5	ug/L	9/5/2013 11:21	PE	EPA 524.2	